

LEED ATTESTATION

Attestation

LEED Product Information acc. to LEED v4 for Building Design and Construction.

Sika certifies based on the present state of knowledge, that the products

Sarnafil® TG 66-12, traffic white 9016

Sarnafil® TG 66-15, traffic white 9016

Sarnafil® TG 66-18, traffic white 9016

Sarnafil® TG 66-20, traffic white 9016

produced in Sarnen, Switzerland, have been tested and evaluated according to the testing method **ASTM E 1980** to calculate the **Solar Reflectance Index (SRI)** at new condition. The Initial Solar Reflectance Index (SRI) for all wind conditions > 82.

The SRI is calculated from Solar Reflectance and Thermal Emissivity values. The Solar Reflectance was determined following ASTM C 1549. The Thermal Emissivity was determined following ASTM C 1371.

The products Sarnafil® TG 66-12, 15, 18 and 20, traffic white 9016 conform on the LEED v4 SS credit 5 option 1 Heat Island reduction – **Roof**. The products can thus contribute to the attainment of 2 full points under this credit.

Sika Services AG

A handwritten signature in black ink, appearing to read "H. Meier".

Heinz Meier

Corporate System Engineer
Solar Roof / Thermal Insulation

Sika Services AG

A handwritten signature in black ink, appearing to read "Koichi Oba".

Koichi Oba

Head Corporate Target Market Roofing

Sarnen, May 2017