


Izoterm Plama d.o.o.  
Podgrad 17  
6244 Podgrad  
SI-Slovenija  
T: +386 (0)5 714 95 02  
F: +386 (0)5 714 95 99  
komerciala@izoterm-plama.si  
www.izoterm-plama.si



The undersigned, representing the following manufacturer:

**Izoterm Plama d.o.o.**  
**Podgrad 17**  
**6244 Podgrad (SLO)**  
**SLOVENIA**

*Manufacturing Plant 1:* Izoterm Plama d.o.o. , Podgrad 17, 6244 Podgrad (SLOVENIA)

*Manufacturing Plant 2:* Izoterm-Plama d.o.o. , Save Kovačevića bb, Industrijska zona, 22320 Indjija, Srbija (SERBIA)

herewith declare that the product families **Plamaflex ISO, Plamaflex SSL, Plamaflex SV**, are in conformity with the provisions of the following EC Directives when installed in accordance with the installation instructions contained in the product documentation:

**89/106/EEC Construction Products Directive**

and that the standards referenced below have been applied:

**EN 14313:2009, »Thermal insulation products for building equipment and industrial installations - Factory made polyethylene foam (PEF) products – Specification«**

Provisions to which the product conforms:

Requirement/Characteristic from the mandate	Requirement clauses in standard	Class
Reaction to fire Euroclass characteristic	4.2.4 Reaction to fire	Euroclass



**IZOTERM**

- Name and Address of Notified Certification Body: ZAG (Zavod za gradbeništvo Slovenije, Dimičeva 12, 1000 Ljubljana, Slovenia)

Name and Address of Notified Laboratories:

- ZAG (Zavod za gradbeništvo Slovenije, Dimičeva 12, 1000 Ljubljana, Slovenia)

Product properties table extract from Certificate of Conformity:

Product	Form	Thickness range	Fire certification	Thermal Conductivity at 10°C
Plamaflex ISO	Tube	4mm – 25mm	Euroclass E	$\lambda < 0,037 \text{ W/mK}$
Plamaflex SSL	Tube	4mm – 25mm	Euroclass E	$\lambda < 0,037 \text{ W/mK}$

Podgrad, 31.5.2013

Saša Zečević  
Izoterm Plama d.o.o.

*Saša Zečević*

**IZOTERM**

Izoterm Plama d.o.o. 8