



# EC CERTIFICATE

## EC – CERTIFICATE OF CONFORMITY 0843 – CPD – 0146

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to construction products (Construction Products Directive – CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

### **Fire Resistant Acrylic Joint Sealant - ACR 240** **Penetration Seal and Linear Joint Seal Classified for use in flexible & solid walls and solid floors**

A sealant used to seal around cables and metallic pipes to form a penetration seal to reinstate the fire resistance performance of wall and floor constructions, where they have been provided with apertures for the penetration of services. The sealant may also be used to seal linear gaps and joints in and between wall and floor constructions to reinstate the fire resistance performance of wall and floor constructions, where they abut or include gaps. Fire Resistant Acrylic Joint Sealant - ACR 240 is supplied in liquid form contained within 310 ml cartridges. The sealant is gunned into the aperture in or between the separating element/elements and where appropriate around the service or services, to a specified depth utilising various backing materials.

placed on the market by

**Würth International AG**  
**Aspermontstrasse 1**  
**CH- 7000 Chur**

and produced in the factory

**A/003**

is submitted by the manufacturer to a Factory Production Control and that the approved body UL International (UK) Ltd., Notified Body 0843 has performed the Initial Type-Testing for the relevant characteristics of the product, the Initial Inspection of the factory and of the Factory Production Control and performs the continuous surveillance, assessment and approval of the Factory Production Control.

This certificate attests that all provisions concerning the attestation of conformity and the performance described in:

**ETA 13/0989, ETA 13/0990, ETAG 026-2, ETAG 026-3**

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on 27<sup>th</sup> June 2013 and remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

First issue date: 27<sup>th</sup> June 2013

Signature

Karl Harland

for UL International (UK) Ltd.



# EC CERTIFICATE

**Annex: Detailed information sheet**

Certificate Number: 0843-CPD-146

**Product/Device description:**

Fire Resistant Acrylic Joint Sealant - ACR 240

**Applicant designation:**

Würth International AG  
Aspermontstrasse 1  
CH- 7000 Chur

**Product Information**

Fire Resistant Acrylic Joint Sealant - ACR 240

The referenced product complies with:

A – All the relevant requirements as per ETA 13/0989, ETA 13/0990, ETAG 026-2, ETAG 026-3

**ETA Valid to date:**

ETA 13/0989 – 20<sup>th</sup> June 2018  
ETA 13/0990 – 20<sup>th</sup> June 2018

Issue date: 27<sup>th</sup> June 2013

Signature

Karl Harland  
for UL International (UK) Ltd.