

# Attestation

## M1

On 2 February 2022 Eurofins Product Testing A/S received a sample of an adhesive with the product name:

**SikaBond® – 151**

supplied by

**Sika Services AG**

The emissions were tested according to 'M1 Protocol for Chemical and Sensory Testing of Building Materials' as published by Rakennustietosäätiö (version of November 2017). Sampling, testing and evaluation were performed according to ISO 16000-3, ISO 16000-6, ISO 16000-9 and ISO 16000-11 (see test report no. 392-2022-00047901\_I\_EN\_rev1).

**The tested product complies with the following requirements:**

---

- The sum of VOC ("TVOC") after 28 days was below the limit of 0.2 mg/m<sup>2</sup>h
  - Formaldehyde after 28 days was below the limit of 0.05 mg/m<sup>2</sup>h
  - Ammonia after 28 days was below the limit of 0.03 mg/m<sup>2</sup>h
  - Carcinogenic substances after 28 days were below the limit of 0.001 mg/m<sup>3</sup>
  - Substances with an EU LCI value have a concentration lower than the LCI value
  - Odour acceptance after 28 days was not worse than the limit of 0.0
- 

This attestation does not alone entitle to use the protected trademark label M1. For the use of an M1, a license has to be applied for at the RTS, Helsinki, Finland.

13 April 2022



Laura Hartung Sørensen  
Analytical Service Manager



Rasmus Verdier  
Analytical Service Manager