

Attestation

EMICODE

On 13 August 2020, Eurofins Product Testing A/S received a sample of self-levelling synthetic resin coating with the product name:

Sikafloor-3000

supplied by

Sika Deutschland GmbH

The emission of organic compounds from the sample was measured in accordance with the test method as defined by GEV in its version by April 2019. See report No. 392-2020-00346001_G_EN.

Evaluation of the test result according to EC 2:

- Carcinogenic substances were not detectable after 3 and after 28 days.
- The sum of VOC ("TVOC") after 3 days was below the limit of 3000 µg/m³.
- The sum of VOC ("TVOC") after 28 days was below the limit of 300 µg/m³.
- The sum of SVOC after 28 day was below the limit of 100 µg/m³.
- The sum of formaldehyde and acetaldehyde after 3 days was below the limit of 0.05 ppm.


This certificate does not alone entitle to use the protected trademark label EMICODE. For the use of an EMICODE label, a license has to be applied for at the GEV, Düsseldorf, Germany.

A license can only be granted for ready-to use products if some additional requirements on contents of certain chemicals (e.g. solvent-free) are fulfilled.

1 October 2020



Pernille Krintel
Analytical Service Manager



Rasmus Stengaard Christensen
Analytical Service Manager, MSc in Chemistry