

# Attestation

## EMICODE

On 13 August 2020, Eurofins Product Testing A/S received a sample of self-levelling synthetic resin coating with the product name:

**Sikafloor-3000FX**

supplied by

**Sika Deutschland GmbH**

The emission of organic compounds from the sample was measured in accordance with the test method as defined by GEV in its version by April 2019. See report No. 392-2020-00346002\_G\_EN.

### Evaluation of the test result according to EC 2:

---

- Carcinogenic substances were not detectable after 3 and after 28 days.
- The sum of VOC ("TVOC") after 3 days was below the limit of 3000 µg/m<sup>3</sup>.
- The sum of VOC ("TVOC") after 28 days was below the limit of 300 µg/m<sup>3</sup>.
- The sum of SVOC after 28 day was below the limit of 100 µg/m<sup>3</sup>.
- The sum of formaldehyde and acetaldehyde after 3 days was below the limit of 0.05 ppm.

---


This certificate does not alone entitle to use the protected trademark label EMICODE. For the use of an EMICODE label, a license has to be applied for at the GEV, Düsseldorf, Germany.

A license can only be granted for ready-to use products if some additional requirements on contents of certain chemicals (e.g. solvent-free) are fulfilled.

1 October 2020



Pernille Krintel  
Analytical Service Manager



Rasmus Stengaard Christensen  
Analytical Service Manager, MSc in Chemistry